

DIN comments on BT N 9636

Provisional draft standardization request on ecodesign and energy labelling of ventilation units

DIN would like to give following comments:

4.1.1, 2. b.

The specific power input should be measured and calculated in $[W/(m^3/h)]$ instead of $[kW/(m^3/h)]$.

4.1.1, 2. d. and 4.1.2., 3. g.

Replace “*sound power level (L_{WA})*”
by “*A-weighted sound power level (L_{WA})*”.

4.1.1, 3. c.

Electric power input should match the same components as effective power input.

Thus replace “*fan drive, including any motor control equipment*”
by “*fans, controls (including remote controls) and the heat pump (if integrated)*”.